## ADDENDUM NO. 1 to UVSC IRRIGATION POND REHABILITATION

#### **BIDDING DOCUMENTS**

#### **JANUARY 4, 2005**

The Bidding Documents, Technical Specifications, and Drawings are hereby revised to include the following changes, deletions, and additions. Contractors Bidding the project shall conform to these revisions and acknowledge receipt of this Addendum on the BID FORM.

#### RESPONSE TO QUESTIONS FROM PRE-BID CONFERENCE

Question: Will the engineer do testing and inspection? Or will it be by a building inspection service?

Answer: Materials testing and inspections will be the responsibility of the Owner per section 01440-3

paragraph 1.11 A.

Question: Bidding documents reference permits, with the contractor to bear the costs thereof. This is a

state project, with no UDOT infringement. Therefore, there are not permit fees as we understand

the system in place. Is this correct?

Answer: There are no foreseen permits needed at this time.

Question: We do not believe this retention pond falls under the auspices of the Corps of Engineers. Is this

correct?

Answer: This retention pond does not fall under the auspices of the Corps of Engineers.

Question: It appears that the concrete to be used is 5,000 psi. This is based on a general note above the

concrete "chart" in the specs. Nothing has been found on the drawings—which typically make

reference to the design strength.

Answer: 5,000 psi strength concrete is to be used.

Question: Drawing CD106 has the words NOT IN CONTRACT diagonally across the page. Details on

this page obviously apply to this project. What is the intent of this? What is not in the contract?

Answer: None of the details on page CD106 apply to this contract or this project. These details are for

the larger pond which is not being bid at this time. ONLY BID THE SMALL POND.

#### **BIDDING REQUIREMENTS**

#### Section 00003-1 & 2

This section will not be required to be signed and turned into the owner. Please sign and turn in the bid form issued with this addendum. The cost breakdown, on the bid schedule, will be the basis for increasing or decreasing the contract amount based on the actual material removed and placed for items 2, 3, and 4.

#### TECHNICAL SPECIFICATIONS

#### Section 01500-1 Paragraph 1.02 A

As per the pre-bid meeting UVSC will not charge for electrical consumption. However temporary power connections will be the responsibility of the CONTRACTOR.

#### Section 03200-4 Paragraph 3.02 E

Splicing will be allowed for the reinforcing bars in the concrete liner system. However splices will need to be stagger and will not be allowed in grade transitions.

#### **DRAWINGS**

- I. None of the details on Sheet CD106 apply to this Contract or the Bid Schedule. These details are for the larger pond which is not being bid at this time. ONLY BID THE SMALL POND.
- II. The bentonite strip shown on Detail C, Sheet CD107 will be placed above the rebar dowels.
- III. The joint sealant on Detail D, Sheet CD107 shall be polyurethane-based, one part elastomeric sealant complying with FS-TT-S00230 Class A type I. (e.g. Sikaflex-1a).
- IV. The joint width shown on Detail D, Sheet CD107 shall be t/6 or 1.667 inches for a 10 inch slab.

THIS ADDENDUM IS HEREBY ATTACHED TO AND MADE A PART OF THE BIDDING DOCUMENTS, AND EACH BIDDER SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN HIS/HER BID.

ADDENDUM NO. 1 IS HEREBY ISSUED ON JANUARY 4, 2005

Delmas W. Johnson, P.E. Project Manager

01/2005 SLB020500 ADDENDUM NO. 1 PAGE 2 OF 2

# **BID FORM**

(Revised)

NAME OF BIDDER	DATE
Γο the Division of Facilities Construction and 4110 State Office Building Salt Lake City, Utah 84114	I Management
the IRRIGATION POND CONCRETE LI and having examined the Contract Document of the conditions surrounding the construction hereby proposes to furnish all labor, materials Contract Documents as specified and within the	o Contractors" and in accordance with the Request for Bids for NER, UTAH VALLEY STATE COLLEGE, OREM, UTAH is and the site of the proposed Work and being familiar with all in of the proposed Project, including the availability of labor, is and supplies as required for the Work in accordance with the time set forth and at the price stated below. This price is to Work required under the Contract Documents of which this bid
/We acknowledge receipt of the following A	ddenda:
BASE BID:	
For all work shown on the Drawings and description for the sum of:	cribed in the Specifications and Contract Documents, I/we agree
	DOLLARS (\$)
In case of discrepancy, written amount shall	govern)

### **BASE BID SCHEDULE:**

This bidder acknowledges that the Owner may elect to increase or decrease the estimated quantities indicated in the following table to reflect conditions encountered during installation of facilities.

ITEM	DESCRIPTION	QTY	UNIT	UNIT COST	TOTAL AMOUNT
1	MOBILIZATION	1	LS		
2	EXCAVATION AND REMOVAL OF LINER, SEDIMENT, AND SUB-BASE MATERIAL	2,400	CY		
3	FURNISH AND INSTALL GEOTEXTILE	28,500	SF		
4	FURNISH AND INSTALL WASHED ROCK/STRUCTURAL FILL	2,000	CY		
5	REINFORCED CONCRETE LINER SYSTEM	1	LS		
6	UNDERDRAIN SYSTEM W/PERFORATED PIPE & SUMP	1	LS		

TOTAL BASE BID:	
I O I AL DASE DID.	

# BID FORM PAGE NO. 2

I/We guarantee that the Work will be Substantially Complete by **March 15, 2005**, should I/we be the successful bidder, and agree to pay liquidated damages in the amount of **\$250.00** per day for each day after expiration of the Contract Time as stated in Article 3 of the Contractor's Agreement.

This bid shall be good for 45 days after bid ope	ening.				
Enclosed is a 5% bid bond, as required, in the sum of					
Type of Organization:					
(Corporation, Partnership, Individual, etc.)  Any request and information related to Utah Pr	reference Laws:				
•	Respectfully submitted,				
	Name of Bidder				
	ADDRESS:				
	Authorized Signature				